Building	Number +Cause of Fire	Fire Related Injuries	Fire Related Deaths	Property Damage
135 E. 12th St.	0	0	0	$0.00
118 W.13th St.	0	0	0	$0.00
84 William St.	0	0	0	$0.00
300 W. 20th St.	0	0	0	$0.00
Stuyvesant	0	0	0	$0.00
23rd St.	0	0	0	$0.00
318 E. 15th St.	3	0	0	$75.00

Cause of fires at 318 E.15th St.-Students placed electric coffee maker on stove top and turned on stove, melting the coffee maker

	Description Fire Safety System			
135 E. 12th St.	Fire Depart ment approved Fire Alarm	Sprinklers entire building	Standpipe in Building	CO Detectors part of Fire Alarm
118 W.13th St.	Fire Depart ment approved Fire Alarm	Sprinklers entire building	Standpipe in Building	CO Detectors part of Fire Alarm
84 William St.	Fire Depart ment approved Fire Alarm	Sprinklers entire building	Standpipe in Building	Hard wired CO detectors
300 W.20th St.	Fire Depart ment approved Fire Alarm	Sprinklers entire building	Standpipe in Building	Battery CO detectors
Stuyvesant	Hard wired smoke detectors in each Apt.	No Sprinkler system	Standpipe in Building	Battery CO detectors
23rd St.	Hard wired smoke detectors in each Apt.	No Sprinkler system	No Standpipe in Building	Hard wired CO detectors
318 E. 15th St.	Fire Department approved Fire Alarm	Sprinklers entire building	Standpipe in Building	Hard wired CO detectors

Housing supplies portable electric heaters when needed
All Buildings with a Fire Department approved Fire Alarm have 4 ↑e at least 4 fire drills per year
No smoking or open flames ie..candles, are allowed in any student housing
All residents of student housing receive Fire Safety Plans as per NYCFD regulations
All students must view a mandatory 1 hour fire safety orientation. The Resident Advisers are given a one hour walk thru in their assigned buildings on fire safety and evacuation procedures dures. This information is given to the residents when they meet with the RA.